

Worksheet **6-4** FACILITY CHECKLIST

SCHOOL DISTRICT: _____
 WORKSHEET COMPLETED BY: _____ ORGANIZATIONAL UNIT: _____
 TELEPHONE: _____ DATE: _____
 NOTES: _____

Parking

General Area/Building: _____ Date: _____ Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is there an adequate number of accessible parking spaces available?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(5)(a); 4.6.1

For guidance in determining the appropriate number of accessible spaces to provide, the table below gives the ADAAG requirements for new construction and alterations (for lots with more than 100 spaces, refer to ADAAG 4.1.2(5)(a)):

Total spaces:	Accessible:
1 to 25	1 space
26 to 50	2 spaces
51 to 75	3 spaces
76 to 100	4 spaces

Are accessible parking spaces at least 8 feet wide, with a 5-foot access aisle (two spaces can share an access aisle)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.3; 4.1.2(5)(a)
--	--------------------------	--------------------------	--------------------------	--	--------------------

Is one in every 8 spaces, but at least one, van-accessible with a 96-inch wide access aisle, and 98 inches of vertical clearance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(5)(b); 4.6.5
---	--------------------------	--------------------------	--------------------------	--	--------------------

Are the access aisles part of the accessible route to an accessible entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.3; 4.3
---	--------------------------	--------------------------	--------------------------	--	------------

Are the accessible spaces the ones closest to an accessible entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.2
---	--------------------------	--------------------------	--------------------------	--	-------

Is the slope of the accessible parking area and access aisle no more than 1:50?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.3
---	--------------------------	--------------------------	--------------------------	--	-------

Are accessible spaces marked with a vertical sign showing the international symbol of accessibility? In addition, are there signs reading "Van Accessible" at van spaces?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.4; 4.30.7
---	--------------------------	--------------------------	--------------------------	--	---------------

Passenger Loading Zones

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is there an access aisle 60 inches wide by 20 feet long adjacent and parallel to the vehicle pull-up space?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(5)(c); 4.6.6
Is the slope of the access aisle and the pull-up space no more than 1:50?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.6
If there is a curb between the access aisle and the vehicle pull-up space, is there a curb ramp?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.6; 4.7
If a walkway crosses or adjoins the driveway and there is no curb, does the walkway edge have a detectable warning surface?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.29.5
Is there at least 114 inches of vertical clearance provided at the accessible passenger loading zones and along at least one vehicle access route to it?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.6.5
Is there a sign displaying the international symbol of accessibility at the accessible loading zone?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(7)(b)

Exterior Route of Travel

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is there at least one accessible route of travel from public transportation stops, accessible parking spaces, accessible passenger loading zones, public streets, and sidewalks to the accessible entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(1); 4.3.2(1)
Is there at least one accessible route that connects accessible buildings, facilities, elements, and spaces that are on the same site?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(2); 4.3.2(2)
Is the accessible route(s) stable, firm and slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.6; 4.5.1
Is the accessible route at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.3
If the accessible route(s) is less than 60 inches wide, are there passing spaces at least 60 inches by 60 inches, or T-intersections of corridors, located at reasonable intervals but not more than 200 feet apart?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.4, Fig. 3
Is there at least 80 inches of clear head room on every route? If an area adjoining an accessible route has less than 80 inches of clear head room, is a barrier to warn persons with visual impairments provided?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.5; 4.4.2; Fig. 8
Are all obstacles along routes of travel cane-detectable (located within 27 inches of the ground or higher than 80 inches, or protruding no more than 4 inches into the route of travel)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.4.1; Fig. 8
If gratings are located in walking surfaces, are the openings of the grating no greater than 1/2 inch wide in one direction? Are the long dimensions of rectangular openings placed perpendicular to the dominant direction of travel?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.4
Is the cross-slope of the accessible route(s) no greater than 1:50?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.7
Is the running slope of the accessible route no greater than 1:20, or is there an accessible ramp if the slope is greater than 1:20 (use ramp survey)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.7
Are walkway level changes no more than 1/4 inch, or if they are between 1/4 inch and 1/2 inch, are they beveled with a slope no greater than 1:2?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.8; 4.5.2
Are there curb cuts, ramps, platform lifts or elevators where there is a change in level greater than 1/2 inch?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.8; 4.5.2
Is there a curb cut wherever an accessible route crosses a curb?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.7.1

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is the slope of the curb ramp no greater than 1:12? If there is not enough space to use a 1:12 slope or less, is the slope of the curb ramp no greater than 1:10 for a maximum rise of 6 inches, or 1:8 for a maximum rise of 3 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.7.2; 4.1.6(3)(a)
Are maximum slopes of adjoining gutters, immediately adjacent road surface, or accessible route no greater than 1:20?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
Is the transition from the curb ramp to adjoining surfaces flush and free of abrupt changes?					4.7.2
If a curb ramp is located where pedestrians must walk across the ramp, or where it is not protected by handrails or guardrails, does it have flared sides with a maximum slope of 1:10?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.7.5
Is the width of the curb ramp, not including the flared sides, no less than 36 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.7.3
Is the surface of the curb ramp stable, firm and slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.1; 4.7.4

Ramps

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are the slopes of ramps no greater than 1:12?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.2
Is the rise of each ramp run (vertical distance between landings) no greater than 30 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.2
Is the cross slope no greater than 1:50?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.6
Do all ramps longer than 6 feet or with more than 6 inches rise, have railings on both sides?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.5
Are railings continuous, sturdy, and between 34 and 38 inches high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.5
Is the width between railings or curbs at least 36 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.3
Are ramps stable, firm, and slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.6; 4.5.1
Is there a 5-foot-long level landing at every 30-foot horizontal length of ramp, at the top and bottom of every ramp and where the ramp changes direction?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.4
Do ramps and landings with drop-offs have walls, railings, projecting surfaces, or curbs at least two inches high to prevent people from slipping off the ramp?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.8.7

Stairs (Note: Stairs are not permitted as part of an accessible route.)

General Area/Building: _____	Date: _____	Reviewer: _____
------------------------------	-------------	-----------------

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Do stairs have closed risers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.9.2
Are stair treads no less than 11 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.9.2
Do stairs have continuous handrails on both sides, with extensions beyond the top and bottom stairs?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.9.4
Do nosings project no more than 1-1/2 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.9.3

Lifts

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
If platform lifts are used, can a person using a wheelchair enter, operate, and exit the lift without assistance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.11.3
Is the platform lift at least 30 by 48 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.11.2; 4.2.4
Is there at least 30 by 48 inches of clear space for a person using a wheelchair to approach to reach the controls and use the lift?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.11.2; 4.2.4
If there is a door on the lift, is the door accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13
Are controls between 15 and 48 inches high (up to 54 inches if a side approach is possible)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.11.2; 4.2.5; 4.2.6
Are the controls operable with one hand, and without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.11.2; 4.27.4

Entrances

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are at least 50% of all public entrances accessible? Is at least one accessible entrance a ground floor entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(8)(a)(1)
Do all inaccessible entrances have signs indicating the location of the nearest accessible entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(8)(d); 4.30
If not all entrances are accessible, are the accessible entrances identified by the international symbol of accessibility?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(7)(c); 4.30
Does at least one door at each accessible entrance have at least 32 inches clear opening (for a double door, at least one 32-inch leaf)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(7)(a); 4.13.4; 4.13.5
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Is the threshold level (less than 1/4 inch high) or beveled with a slope no greater than 1:2 up to 1/2 inch high (3/4" maximum for exterior sliding doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
Are door handles at accessible entrances no higher than 48 inches and operable with one hand and without tight grasping, pinching or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
If there is a revolving door or turnstile at an entrance, is there an accessible door or gate next to it?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.2
On sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Can accessible doors be opened without too much force (maximum is 5 lbf for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
If the accessible doors have closers, do they take at least 3 seconds to close to a point 3 inches from the latch?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.10

Lobbies and Corridors

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Does the accessible entrance connect with all accessible elements and spaces in the building?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(1); 4.3.2(3)
Is the accessible route to all public spaces at least 36 inches wide? If the accessible route turns around an obstruction less than 48 inches wide, is the route at least 42 inches wide on the approach to and exit from the turn and at least 48 inches wide at the base of the turn?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.3; Fig. 7
Is the cross-slope of the accessible route no steeper than 1:50?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.7
If the accessible route is less than 5 feet wide, are there passing spaces 5 feet by 5 feet or T-intersecting corridors located at reasonable intervals no more than 200 feet apart?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.4; Fig. 3
Is there at least 80 inches of clear head room on every route? If an area adjoining an accessible route has less than 80 inches of clear head room, is a barrier to warn persons with visual impairments provided?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.5; 4.4.2; Fig. 8
Are floors on an accessible route stable, firm, and slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.1
Is the slope no more than 1:20, or is there a ramp when the slope is greater than 1:20?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.7
If objects mounted to the wall have leading edges between 27 and 80 inches from the floor, do they project no more than 4 inches into the route of travel?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.4.1
Are walkway level changes less than 1/4 inch, or, if they are between 1/4 inch and 1/2 inch, are they beveled with a slope no greater than 1:2?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.8; 4.5.2
Are ramps provided for changes in level greater than 1/2 inch?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.2
Does at least one door into each public space have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(7)(b); 4.13.5
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled with a slope no greater than 1:2, up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
Do signs which provide direction to, or information about, functional spaces of the building, comply with the appropriate requirements for directional signage?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(b); 4.30
Do signs designating permanent rooms and spaces, such as rest room signs, signs at exit doors, and room numbers, comply with the appropriate requirements for tactile signage? Do all signs meet legibility requirements regarding contrast and character proportion?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(a); 4.30
Do alarms have both visible and audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(14); 4.28

Elevators

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Does the elevator have automatic operation and self-leveling features?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.2
Are there both visible and verbal or audible door opening/closing and floor indicators (one tone = up, two tones = down)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.4
Are the call buttons in the hallway at least 3/4 inches wide and centered at 42 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.3
Do hall call buttons have visual signals to indicate when each call is registered and answered?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.3
Is there a sign on the jamb at each floor identifying the floor in raised and Braille letters?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.5; 4.30.4
Is the door opening at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.9
For a centered opening, is the minimum inside dimension of elevator cars 51 inches by 80 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.9
For an off-center opening, is the minimum inside dimension of elevator cars 51 inches by 68 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.9
Are car control buttons no higher than 48 inches for forward reach and 54 inches for side reach?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.12(3)
Do the controls inside the cab have raised and Braille lettering?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.12(2); 4.30.4
Are the emergency controls grouped at the bottom of the control panel and centered no less than 35 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.12(3)
If an emergency intercom is provided, is it usable without voice communication?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.14
Is the emergency intercom identified by Braille and raised letters and a raised symbol?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.14; 4.30.4
If the communication system is in a closed compartment, is the hardware on the compartment operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.10.14

Rooms and Spaces

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are all aisles and pathways to materials and services at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.3
If aisles between fixed furniture are less than 5 feet wide, are there passing spaces 5 feet by 5 feet or intersecting aisles at reasonable intervals not exceeding 200 feet maximum?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.4
Are floors stable, firm, and slip-resistant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.1
Is carpeting low-pile, tightly woven, and securely attached?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.5.3
In routes through public areas, are all obstacles cane-detectable (located within 27 inches of the floor or higher than 80 inches, or protruding not more than 4 inches from the wall)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.4.1; Fig. 8
Is there at least 80 inches of clear head room on every route? If an area adjoining an accessible route has less than 80 inches of clear head room, is a barrier to warn persons with visual impairments provided?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.5; 4.4.2; Fig. 8
Does at least one door into each public space have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.5; 4.1.3(7)(b)
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Do signs designating permanent rooms and spaces, such as rest room signs, signs at exit doors, and room numbers, comply with the appropriate requirements for signage? Do all signs meet legibility requirements regarding contrast and character proportion?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(a); 4.30

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Do signs which provide direction to, or information about, functional spaces of the building comply with the appropriate requirements for directional signage?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(b); 4.30
Are all controls that are available for use by the public (including electrical, mechanical, cabinet, game, and self-service controls) located between 15 and 48 inches for forward reach and between 9 and 54 inches for side reach?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.2.5; 4.2.6
Are they operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.27.4
If fixed or built-in seating or tables are provided in accessible public or common use areas, do at least 5%, but not less than one, of the fixed or built-in seating areas or tables provide 30 inches by 48 inches of clear floor space?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(18); 4.32.2
Are the aisles between fixed seating at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.3.3
Are the tops of at least 5% of fixed tables or counters between 28 and 34 inches high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.32.4
Are knee spaces at accessible fixed tables at least 27 inches high, 30 inches wide, and 19 inches deep?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.32.3
Are at least 50% of drinking fountains, but at least one, on each floor accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(10); 4.15
Do the accessible wall- and post-mounted cantilevered units have clear knee space 27 inches high, 30 inches wide and 17 to 19 inches deep? Do these units have a minimum clear floor space 30 inches by 48 inches to allow a person who uses a wheelchair to approach the unit facing forward?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.15.5(1)
Do the accessible free-standing or built-in drinking fountains not having a clear space under them have clear floor space of at least 30 by 48 inches in front to allow a parallel approach to the unit?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.15.5(2)
Do the accessible drinking fountains have spouts no higher than 36 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.15.2
Are controls on accessible drinking fountains mounted on the front or on the side near the front edge, and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.15.4; 4.27.4
If pay or public-use phones are provided, is there clear floor space of at least 30 by 48 inches in front of at least one in each bank, that allows a parallel or perpendicular approach by a person using a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(17)(a), 4.31.2
Are the operable parts of the accessible phone(s) 15 to 48 inches high (9 to 54 inches if a side approach is possible)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.31.3; 4.2.5; 4.2.6

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Do the accessible phones have push-button controls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.31.6
Are the accessible phones hearing-aid compatible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.31.5(1)
Are the accessible phones adapted with volume control? In addition, do 25%, but not less than one, of all other public phones have volume control?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(17)(b); 4.31.5(2)
Are the accessible phones and all the phones with volume control identified with appropriate signage?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(17)(b); 4.30
If there are four or more public phones in the building, is one of the phones equipped with a text telephone (TT or TDD)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(17)(c)
Is the location of the text telephone identified by accessible signage bearing the international TDD symbol?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.30.7(3)
When a bank of telephones consists of three or more public pay phones, is at least one public pay phone equipped with a shelf and outlet?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(17); 4.31.9(2)
Do all banks of telephones that do not contain a text telephone have appropriate directional signage placed adjacent to them indicating the location of the text telephone? If the facility has no banks of telephones, is there appropriate directional signage provided at the entrance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.30.7(3)
Do alarms have both visible and audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(14); 4.28

Toilet Rooms

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
If rest rooms are available to the public, is at least one rest room on each floor that has public rest rooms (either one for each sex, or unisex) on an accessible route and fully accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	4.1.2(6); 4.1.3(11); 4.1.6(3)(e); 4.22; Fig. 30	
Are there signs at inaccessible rest rooms that give directions to accessible ones?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.6(3)(e)(iii); 4.30
When not all toilet facilities are accessible, are accessible toilet rooms identified by the international symbol of accessibility?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(7)(d)
Do doors have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.22.2
Are appropriate maneuvering clearances provided at doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Is there tactile signage identifying the rest rooms, placed on the wall at the latch side of the door, centered 60 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(a); 4.30
Is there a 5-foot diameter clear space or a T-shaped space in the rest room to make turns?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.22.3
Are all fixtures on an accessible route?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.22.7; 4.27

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is there at least one wheelchair-accessible stall that is at least 5 feet wide, clear of the door swing, and at least 56 inches long if the toilet is wall-mounted or 59 inches long if the toilet is floor-mounted? If it is technically infeasible to provide such a standard stall, is there a stall that is either 36 by 66 inches or 48 by 66 inches if the toilet is wall-mounted or either 36 by 69 inches or 48 by 69 inches if the toilet is floor-mounted?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.17.3; 4.22; Fig. 30
Can the door to the accessible toilet stall be operated without twisting or fine movement, on both the inside and outside?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.17.5; 4.13.9
Do the accessible toilet stalls have a minimum door opening of at least 32 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.17.5; 4.13.5
Are there accessible grab bars in accessible toilet stalls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.17.6; 4.26; Fig. 30
Are there accessible grab bars at accessible water closets not located in stalls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.16.4; 4.26; Fig. 29
Are the accessible toilet seats 17 to 19 inches high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.16.3
Are the flush controls on accessible toilets no higher than 44 inches and mounted on the wide side of toilet areas?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.16.5
Is the toilet paper dispenser at least 19 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.16.6
Does one lavatory have a 30-inch-wide by 48-inch-deep clear space in front, with a maximum of 19 inches of that depth under the lavatory?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.3
Is the lavatory rim no higher than 34 inches from the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.2
Is there at least 29 inches from the floor to the bottom of the lavatory apron?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.2
Is there at least 8 inches of clearance toward the wall provided for knee clearance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.2; Fig. 31
Is there a maximum of 6 inches of clearance outward from the wall provided for toe clearance?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.2; Fig. 31
Can the faucet be operated with one hand and without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.5
Are hot water pipes and drain pipes insulated, or configured to avoid contact with the legs of a person using a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.4

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are soap and other dispensers and hand dryers no higher than 48 inches for forward reach or 54 inches for side reach?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.27.3
Can they be operated with one hand and without twisting or fine movement?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.27.4
Is there a clear floor space of 30 by 48 inches in front of the dispensers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.27.2
Is the mirror mounted with the bottom edge of the reflecting surface no higher than 40 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.19.6
If alarms are provided in the rest room, do they have both visual and audible signals?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(14); 4.28

Shower Rooms

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are shower rooms on an accessible route and fully accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(11); 4.23.1
When not all shower rooms are accessible, are accessible shower rooms identified by the international symbol of accessibility?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.2(7)(d)
Do doors have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.5
Are appropriate maneuvering clearances provided at doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.11
Are door handles 48 inches high or less and operable with one hand and without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.2; 4.13.9
Is there tactile signage identifying the shower rooms, placed on the wall at the latch side of the door, centered 60 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(16)(a); 4.30
Is there a 5-foot diameter clear space or a T-shaped space in the rest room to make turns?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.23.3
If a standard shower stall is provided, is it at least 36 inches by 36 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.2; Fig. 35
If a roll-in shower stall is provided, is it at least 30 inches by 60 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.2; Fig. 35
Is appropriate clear floor space provided at shower stalls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.2; Fig. 35
Is a seat provided in shower stalls 36 inches by 36 inches? Is it mounted between 17 and 19 inches above the shower floor on the wall opposite the controls and does it extend the full depth of the stall?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.3; 4.26.3

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Where a fixed seat is provided in a 30 by 60 inch minimum shower stall, is it a folding type and is it mounted on the wall adjacent to the controls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.3; 4.26
Are accessible grab bars provided in accessible shower stalls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.4; Fig. 37
Are accessible faucets and other controls that are operable with one hand and without tight grasping, pinching, or twisting of the wrist provided in accessible shower stalls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.5; 4.27.4; Fig. 37
If provided, are curbs in shower stalls 36 inches by 36 inches no higher than 1/2 inch?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.7
If a 30 by 60 inch shower stall is provided, does it have no curb?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.21.7

Assembly Areas

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Does at least one door into each public space have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(7)(b); 4.13.5
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
In assembly areas with fixed seating, is the required number of wheelchair locations provided (see table at §4.1.3(19)(a) of ADAAG)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(19)(a)
Is each wheelchair space at least 48 inches deep for approach from the front or rear, and 60 inches deep for approach from the side?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.33.2
Do wheelchair spaces adjoin an accessible route that also serves as an accessible means of egress?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.33.3
Is at least one companion fixed seat provided next to each wheelchair seating area?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.33.3
Does an accessible route connect wheelchair seating locations with performing areas, including stages, arena floors, dressing rooms, locker rooms, and other spaces used by performers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.33.5
In assembly areas where audible communications are integral to the use of the space, are an adequate number of assistive listening systems provided?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(19)(b)
Is there signage indicating the availability of the assistive listening devices?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(19)(b)

Cafeterias

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Does at least one door into each public space have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(7)(b); 4.13.5
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are at least 5%, but a minimum of one, of the fixed tables accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(18); 5.1
Is the knee space at accessible tables at least 27 inches high, 30 inches wide, and 19 inches deep?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.32.3
Is the top of each accessible table or counter between 28 and 34 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.32.4
Where possible, are the accessible tables or counters distributed throughout the space?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.1
Are all aisles between accessible fixed tables at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.3
Where counter service is provided, is there at least a 60 inch long portion of the main counter that is no more than 34 inches high and that has at least 27 inches of knee space below or is service available at accessible tables within the same area?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.2
Do food service lines have at least 36 inches clear width?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.5

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Are tray slides no more than 34 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.5
Are at least 50% of self-service food service shelves 15 to 48 inches for perpendicular approach and 9 to 54 inches for parallel approach?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.5
Are self-service shelves and dispensing devices for tableware, dishware, condiments, food, and beverages installed 15 to 48 inches for forward approach or 9 to 54 inches for parallel approach?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.6; 4.2
Do self-service shelves and vending machines have at least a 30- by 48-inch clear floor space?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.6; 5.8; 4.2
Are vending machines on an accessible route?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		5.8; 4.2.4

Libraries

General Area/Building: _____

Date: _____

Reviewer: _____

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Does at least one door into each public space have at least a 32-inch clear opening?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.1.3(7)(b); 4.13.5
Are appropriate maneuvering clearances provided at accessible doors?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.6; Fig. 25
Can doors be opened without too much force (5 lbf maximum for interior doors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.11
Are door handles 48 inches high or less and operable without tight grasping, pinching, or twisting of the wrist?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
Are all thresholds level (less than 1/4 inch), or beveled, with a slope no greater than 1:2 up to 1/2 inch high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.8
If there are sliding doors, is the operating hardware exposed and usable from both sides when the doors are fully open?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		4.13.9
If there is a turnstile or security device, is there an accessible door or gate adjacent to it?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.3; 4.13
Is at least one lane for each check-out area accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.3
Are at least 5% (but a minimum of one) of fixed seating, tables or study carrels accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.2
Is there a clear floor space of 30 by 48 inches for wheelchair spaces at accessible tables?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.2; 4.2
Are the tops of the accessible fixed tables between 28 and 34 inches above the floor?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.2; 4.32.4
Is there knee space under the accessible, fixed tables at least 27 inches high, 30 inches wide and 19 inches deep?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.2; 4.32.3
Are the aisles leading up to and between accessible tables and carrels at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.2; 4.2.3
Is the clear aisle space at card catalogs and magazine displays at least 36 inches wide?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.4

ADA Self-Evaluation and Transition Planning for Public Schools

Questions	In Compliance?			Dimensions/Comments	ADAAG
	Y	N	NA		
Is the minimum clear aisle width between stacks at least 36 inches?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.5
Are card catalogs between 18 and 54 inches high?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		8.4